

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 10/8/18

Obtained: 20/8/18

Published: 3/9/18

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	23	200	µg/L	No
		Electrical Conductivity	1990	1780	µS/cm	No
		Nickel	76	200	µg/L	No
		Oil and Grease	5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	30	mg/L	No
		Turbidity	3.8	150	NTU	No
		Zinc	239	300	µg/L	No