

**License Holder:** Tahmoor Coal Pty Ltd  
**Site Address:** Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573  
**EPL Number:** 1389

**Sampled:** 9/4/18  
**Obtained:** 17/4/18  
**Published:** 26/4/18

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	51	200	µg/L	No
		Electrical Conductivity	2000	2600	µS/cm	No
		Nickel	51	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	6	30	mg/L	No
		Turbidity	0.8	150	NTU	No
		Zinc	44	300	µg/L	No