

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 8/2/18

Obtained: 26/2/18

Published: 27/2/18

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	88	200	µg/L	No
		Electrical Conductivity	2230	2600	µS/cm	No
		Nickel	68	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.5	6.5-9.0	units	No
		Total Suspended Solids - TSS	7	30	mg/L	No
		Turbidity	1.1	150	NTU	No
		Zinc	52	300	µg/L	No