

License Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389

Sampled: 8/12/16
Obtained: 16/12/16
Published: 20/12/16

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	55	200	µg/L	No
		Electrical Conductivity	1720	2600	µS/cm	No
		Nickel	55	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.4	6.5-9.0	units	No
		Total Suspended Solids - TSS	7	30	mg/L	No
		Turbidity	1.6	150	NTU	No
		Zinc	44	300	µg/L	No