

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 19/8/16

Obtained: 25/8/16

Published: 2/9/16

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	52	200	µg/L	No
		Electrical Conductivity	1800	2600	µS/cm	No
		Nickel	52	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.3	6.5-9.0	units	No
		Total Suspended Solids - TSS	15	30	mg/L	No
		Turbidity	21.4	150	NTU	No
		Zinc	94	300	µg/L	No