

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31439&SYSUID=1&LICID=1389>

Sampled: Continuous

Obtained: 4 July 2016

Published: 5 July 2016

Sampling Point	Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. Value	Max. Value	Limit	Exceedance (yes/no)
1	Volume	kL	Continuous	Continuous	1596	38999*	15500	No

*38999 kL occurred on 5 June 2016 - It was over this weekend that Tahmoor Underground received 310mm of rainfall. This discharge is not an exceedance as there was more than 10mm of rainfall on the day.