

License Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389

Sampled: 08/04/16
Obtained: 15/04/16
Published: 20/04/16

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedance (yes/no)
1	Monthly	Arsenic	95	200	µg/L	No
		Electrical Conductivity	2050	2600	µS/cm	No
		Nickel	68	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.4	6.5-9.0	units	No
		Total Suspended Solids - TSS	7	30	mg/L	Yes*
		Turbidity	14.2	150	NTU	No
		Zinc	81	300	µg/L	No

*During April additional water testing was completed as part of a project on site. Monitoring identified an exceedance of Tahmoor Coal's Environmental Protection Licence. On 1 April 2016 the suspended solids was 34 mg/L compared with the limit of 30 mg/L.