

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 6/8/15

Obtained: 14/8/15

Published: 28/8/15

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	30	200	µg/L	No
		Electrical Conductivity	2210	2600	µS/cm	No
		Nickel	83	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	10	30	mg/L	No
		Turbidity	12	150	NTU	No
		Zinc	87	300	µg/L	No