

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 10 September 2014

Obtained: 18 September 2014

Published: 24 September 2014

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	58	200	µg/L	No
		Electrical Conductivity	1920	2600	µS/cm	No
		Nickel	51	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.5	6.5-9.0	units	No
		Total Suspended Solids - TSS	16	30	mg/L	No
		Turbidity	14.2	150	NTU	No
		Zinc	95	300	µg/L	No