

**License Holder:** Tahmoor Coal Pty Ltd  
**Site Address:** Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573  
**EPL Number:** 1389

**Sampled:** 10 April 2013

**Obtained:** 29 April 2013

**Published:** 30 April 2013

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	74	200	µg/L	No
		Electrical Conductivity	1940	2600	µS/cm	No
		Nickel	101	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.4	6.5-9.0	units	No
		Total Suspended Solids - TSS	23	30	mg/L	No
		Turbidity	22.1	150	NTU	No
		Zinc	114	300	µg/L	No
4	Monthly during discharge	Arsenic	3	200	µg/L	No
		Electrical Conductivity	1390	2600	µS/cm	No
		Nickel	15	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	9	50	mg/L	No
		Zinc	<5	300	µg/L	No
6	Monthly during discharge	Electrical Conductivity	316	-	µS/cm	No
		Oil and Grease	<5	10	mg/L	No
		pH	7.2	6.5-9.0	units	No
		Total Suspended Solids - TSS	<6	50	mg/L	No