

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31439&SYSUID=1&LICID=1389>

Sampled: 11 July 2013

Obtained: 22 July 2013

Published: 23 July 2013

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	55	200	µg/L	No
		Electrical Conductivity	1820	2600	µS/cm	No
		Nickel	47	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	30	30	mg/L	No
		Turbidity	22.4	150	NTU	No
		Zinc	80	300	µg/L	No
4	Monthly during discharge	Arsenic	4	200	µg/L	No
		Electrical Conductivity	1380	2600	µS/cm	No
		Nickel	16	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.5	6.5-9.0	units	No
		Total Suspended Solids - TSS	7	50	mg/L	No
		Zinc	10	300	µg/L	No
6	Monthly during discharge	Electrical Conductivity		-	µS/cm	No
		Oil and Grease	<5	10	mg/L	No
		pH	7.2	6.5-9.0	units	No
		Total Suspended Solids - TSS	8	50	mg/L	No