

License Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389

Sampled: 12 June 2013
Obtained: 20 June 2013
Published: 26 June 2013

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	71	200	µg/L	No
		Electrical Conductivity	1890	2600	µS/cm	No
		Nickel	70	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.8	6.5-9.0	units	No
		Total Suspended Solids - TSS	20	30	mg/L	No
		Turbidity	30.8	150	NTU	No
		Zinc	83	300	µg/L	No
4	Monthly during discharge	Arsenic	4	200	µg/L	No
		Electrical Conductivity	1620	2600	µS/cm	No
		Nickel	21	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	9	6.5-9.0	units	No
		Total Suspended Solids - TSS	14	50	mg/L	No
		Zinc	7	300	µg/L	No
6	Monthly during discharge	Electrical Conductivity	353	-	µS/cm	No
		Oil and Grease	<5	10	mg/L	No
		pH	7.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	50	mg/L	No