

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31439&SYSUID=1&LICID=1389>

Sampled: 11 March 2013

Obtained: 18 March 2013

Published: 20 March 2013

| Sampling Point | Monitoring frequency required by licence | Pollutant | Measurement | Limit | Unit | Exceedence (yes/no) |
|----------------|--|------------------------------|-------------|---------|-------|---------------------|
| 1 | Monthly | Arsenic | 76 | 200 | µg/L | No |
| | | Electrical Conductivity | 1940 | 2600 | µS/cm | No |
| | | Nickel | 90 | 200 | µg/L | No |
| | | Oil and Grease | <5 | 10 | mg/L | No |
| | | pH | 8.4 | 6.5-9.0 | units | No |
| | | Total Suspended Solids - TSS | 11 | 30 | mg/L | No |
| | | Turbidity | 6.1 | 150 | NTU | No |
| | | Zinc | 77 | 300 | µg/L | No |
| 4 | Monthly during discharge | Arsenic | 13 | 200 | µg/L | No |
| | | Electrical Conductivity | 865 | 2600 | µS/cm | No |
| | | Nickel | 13 | 200 | µg/L | No |
| | | Oil and Grease | <5 | 10 | mg/L | No |
| | | pH | 8.5 | 6.5-9.0 | units | No |
| | | Total Suspended Solids - TSS | 37 | 50 | mg/L | No |
| | | Zinc | 6 | 300 | µg/L | No |
| 6 | Monthly during discharge | Electrical Conductivity | 267 | - | µS/cm | No |
| | | Oil and Grease | <5 | 10 | mg/L | No |
| | | pH | 7.4 | 6.5-9.0 | units | No |
| | | Total Suspended Solids - TSS | 5 | 50 | mg/L | No |