

License Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389

Sampled: 11 September 2013

Obtained: 18 September 2013

Published: 19 September 2013

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	34	200	µg/L	No
		Electrical Conductivity	1060	2600	µS/cm	No
		Nickel	26	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.5	6.5-9.0	units	No
		Total Suspended Solids - TSS	13	30	mg/L	No
		Turbidity	7.7	150	NTU	No
		Zinc	64	300	µg/L	No

Note: Tahmoor Colliery's Environmental Protection Licence has been altered. Please see the Approvals section to read new EPL