

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31439&SYSUID=1&LICID=1389>

Sampled: 11 April
2012

Obtained: 23 April
2012

Published: 8 June 2012

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	106	200	µg/L	No
		Electrical Conductivity	2420	2600	µS/cm	No
		Nickel	89	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.5	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	30	mg/L	No
		Turbidity	<0.1	150	NTU	No
		Zinc	68	300	µg/L	No
4	Monthly during discharge	Arsenic	2	200	µg/L	No
		Electrical Conductivity	1450	2600	µS/cm	No
		Nickel	15	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	50	mg/L	No
		Zinc	<5	300	µg/L	No
		6	Monthly during discharge	Electrical Conductivity	381	-
Oil and Grease	<5			10	mg/L	No
pH	7.2			6.5-9.0	units	No

		Total Suspended Solids - TSS	<5	50	mg/L	No
--	--	------------------------------------	----	----	------	----