

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31439&SYSUID=1&LICID=1389>

Sampled: 8 August 2012

Obtained: 20 August 2012

Published: 23 August 2012

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	124	200	µg/L	No
		Electrical Conductivity	2190	2600	µS/cm	No
		Nickel	78	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.4	6.5-9.0	units	No
		Total Suspended Solids - TSS	8	30	mg/L	No
		Turbidity	8.6	150	NTU	No
		Zinc	122	300	µg/L	No
4	Monthly during discharge	Arsenic	20	200	µg/L	No
		Electrical Conductivity	1660	2600	µS/cm	No
		Nickel	32	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.7	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	50	mg/L	No
		Zinc	27	300	µg/L	No
6	Monthly during discharge	Electrical Conductivity	446	-	µS/cm	No
		Oil and Grease	<5	10	mg/L	No
		pH	7.7	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	50	mg/L	No