

License Holder: Tahmoor Coal Pty Ltd  
 Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573  
 EPL Number: 1389

Sampled: 8 June 2012  
 Obtained: 19 June 2012  
 Published: 3 July 2012

| Sampling Point | Monitoring frequency required by licence | Pollutant                    | Measurement | Limit   | Unit  | Exceedence (yes/no) |
|----------------|--|------------------------------|-------------|---------|-------|---------------------|
| 1              | Monthly                                  | Arsenic                      | 111         | 200     | µg/L  | No                  |
|                |  | Electrical Conductivity      | 1630        | 2600    | µS/cm | No                  |
|                |  | Nickel                       | 63          | 200     | µg/L  | No                  |
|                |  | Oil and Grease               | <5          | 10      | mg/L  | No                  |
|                |  | pH                           | 8.8         | 6.5-9.0 | units | No                  |
|                |  | Total Suspended Solids - TSS | 16          | 30      | mg/L  | No                  |
|                |  | Turbidity                    | 15          | 150     | NTU   | No                  |
|                |  | Zinc                         | 93          | 300     | µg/L  | No                  |
| 4              | Monthly during discharge                 | Arsenic                      | 6           | 200     | µg/L  | No                  |
|                |  | Electrical Conductivity      | 1100        | 2600    | µS/cm | No                  |
|                |  | Nickel                       | 20          | 200     | µg/L  | No                  |
|                |  | Oil and Grease               | <5          | 10      | mg/L  | No                  |
|                |  | pH                           | 8.8         | 6.5-9.0 | units | No                  |
|                |  | Total Suspended Solids - TSS | 16          | 50      | mg/L  | No                  |
|                |  | Zinc                         | 7           | 300     | µg/L  | No                  |
| 6              | Monthly during discharge                 | Electrical Conductivity      | 0           | -       | µS/cm | No                  |
|                |  | Oil and Grease               | 0           | 10      | mg/L  | No                  |
|                |  | pH                           | 0           | 6.5-9.0 | units | No                  |
|                |  | Total Suspended Solids - TSS | 0           | 50      | mg/L  | No                  |