

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31439&SYSUID=1&LICID=1389>

Sampled: 9 October
2012

Obtained: 19 August
2012

Published: 25 October 2012

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	127	200	µg/L	No
		Electrical Conductivity	2150	2600	µS/cm	No
		Nickel	84	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	8	30	mg/L	No
		Turbidity	7.7	150	NTU	No
		Zinc	66	300	µg/L	No
4	Monthly during discharge	Arsenic	15	200	µg/L	No
		Electrical Conductivity	1780	2600	µS/cm	No
		Nickel	31	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	9	6.5-9.0	units	No
		Total Suspended Solids - TSS	6	50	mg/L	No
		Zinc	6	300	µg/L	No
6	Monthly during discharge	Electrical Conductivity	1610	-	µS/cm	No
		Oil and Grease	<5	10	mg/L	No
		pH	7.4	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	50	mg/L	No