

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 10 September 2012

Obtained: 19 September 2012

Published: 19 September 2012

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	86	200	µg/L	No
		Electrical Conductivity	2110	2600	µS/cm	No
		Nickel	62	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.7	6.5-9.0	units	No
		Total Suspended Solids - TSS	18	30	mg/L	No
		Turbidity	19	150	NTU	No
		Zinc	34	300	µg/L	No
4	Monthly during discharge	Arsenic	6	200	µg/L	No
		Electrical Conductivity	1880	2600	µS/cm	No
		Nickel	26	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	9	6.5-9.0	units	No
		Total Suspended Solids - TSS	10	50	mg/L	No
		Zinc	<5	300	µg/L	No
		6	Monthly during discharge	Electrical Conductivity	0	-
Oil and Grease	0			10	mg/L	No
pH	0			6.5-9.0	units	No
Total Suspended Solids - TSS	0			50	mg/L	No