

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 11/7/19

Obtained: 18/7/19

Published: 2/8/19

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	50	200	µg/L	No
		Electrical Conductivity	1910	2600	µS/cm	No
		Nickel	64	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.7	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	30	mg/L	No
		Turbidity	7.8	150	NTU	No
		Zinc	94	300	µg/L	No