

Licence Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389



Sampled: 14/08/2020
Obtained: 28/08/2020
Published: 31/08/2020

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedance (yes/no)
1	Monthly	Arsenic	50	200	µg/L	No
		Electrical Conductivity	1900	2600	µS/cm	No
		Nickel	53	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.8	6.5-9.0	units	No
		Total Suspended Solids - TSS	17	30	mg/L	No
		Turbidity	16.9	150	NTU	No
		Zinc	53	300	µg/L	No