

Licence Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389



Sampled: 9/4/20, 17/4/20, 18/4/20,

19/4/20, 20/4/20, 21/4/20,

22/4/20, 24/4/20, 27/4/20

Obtained: 3/06/20

Published: 3/06/20

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement		Limit	Unit	Exceedence (yes/no)
			Min	Max			
1	Monthly	Arsenic	13	78	200	µg/L	No
		Electrical Conductivity	1860	2310	2600	µS/cm	No
		Nickel	1	72	200	µg/L	No
		pH	7.46	8.9	6.5-9.0	units	No
		Total Suspended Solids - TSS	11	418	30	mg/L	Yes
		Turbidity	1.3	488	150	NTU	Yes
		Zinc	10	73	300	µg/L	No
		Copper	1.0	9.0*	1.4	µg/L	Yes

* higher than 95% ANZECC Guideline Trigger Values