

**Licence Holder:** Tahmoor Coal Pty Ltd  
**Site Address:** Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573  
**EPL Number:** 1389



**Sampled:** 8/12/2020  
**Obtained:** 21/12/2020  
**Published:** 22/12/2020

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedance (yes/no)
1	Monthly	Arsenic	105	200	µg/L	No
		Electrical Conductivity	2350	2600	µS/cm	No
		Nickel	74	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	5	30	mg/L	No
		Turbidity	3.9	150	NTU	No
		Zinc	49	300	µg/L	No